


FENCE REQUIREMENTS

For Wastewater Lagoons in Marion County

Lagoons are required to be fenced before occupancy. The lagoon fence must be a minimum of 48 inches in height, with openings in the fence no larger than 2 inches by 4 inches. The fence may be made of welded wire or chain link. The gate must be a minimum of 4 feet wide, for access. The fence post may be made of wood or steel. Wire for the fence must be 14 gauge or better.

Fence Material



Chain Link



2" x 4" Welded Wire

Fence Placement

